

# WARREN RECC'S ADDITIONAL REQUIREMENTS

- Page 5  
1-1 Warren RECC provides all permanent service meter sockets up through 400 amperes (except meter socket-transfer switch combinations and special order gang boxes, which also must meet Warren RECC's specifications.)
- Page 6  
1-8 Temporary poles will be reinspected each time they are placed into service. (See Diagram 3-A, Page 21.) Warren RECC will provide service to temporary service poles once inspected by authority having jurisdiction and which have an on-site health department permit, where required.
- Page 14  
2-67 Special permission may be granted by the authority having jurisdiction to allow "service only" power (no occupancy permitted). Electrical provisions to complete construction must be available and must meet construction site requirements.
- Page 16  
3-3 Conduit mast risers shall be 2 1/2-inch rigid grade galvanized steel conduit (not water pipe) for services up through 225 amperes, and 3-inch conduit for services over 225 amperes, up to 400 amperes. (See Diagram 3-B, Note 3, Page 22.)
- Page 17  
3-5 Underground service laterals for services of 200 amperes shall be placed in 2 1/2-inch approved schedule 40 PVC conduit. For underground service lateral of greater than 200 amperes, a 3-inch approved schedule 40 PVC conduit shall be used. Conduit shall contain no more than three bends all of which can be 90 degrees with a minimum sweep radius of 18 inches. Elbows shall be schedule 80 PVC where conduit length is greater than 150 feet. Maximum conduit length shall be 250 feet with pull line installed. The expansion joint must be located above final grade to facilitate ground movement or settling. (See Diagram 3-D, Note 4, Page 24 .)
- Contact your local Warren RECC office for an inspection prior to backfilling the trench, after conduit and pull string are installed.
- Page 70  
15-2 Service pedestal shall be stabilized using a minimum of 6 inches of concrete. Ownership of the pedestal and responsibility for maintenance belongs to the property owner.
- 15-2, C Service pedestal shall not restrict the mobile home door openings or impede the safe access to the home. (See Diagram 15-D, Page 78.)
- 15-2, E Circuit breakers, changed or added to the pedestal, must be listed as approved by the service pedestal manufacturer.