



PRIMARY DITCH DETAIL 1A

N.T.S.

NOTES:

- | | |
|---|--|
| <p>1) CONDUIT SHALL BE PVC, SCHEDULE 40 ELECTRICAL GRADE PVC, SIZE AND NUMBER AS SPECIFIED ON PLANS. SWEEPS SHALL BE SCHEDULE 80, 36" RADIUS.</p> <p>2) WARNING TAPE SHALL BE INSTALLED THE LENGTH OF THE TRENCH 12" ABOVE CONDUIT.</p> <p>3) TELEPHONE OR CABLE UTILITY MINIMUM SEPARATION FROM W.R.E.C.C. DUCTS SHALL BE 12" PARALLEL AND 12" VERTICAL.</p> | <p>4) ALL FOREIGN UTILITY PERPENDICULAR CROSSINGS MUST HAVE 12" MINIMUM SEPARATION FROM W.R.E.C.C. DUCT.</p> <p>5) CONDUITS RUNNING HORIZONTAL TO WATER OR GAS LINES MUST HAVE A MINIMUM 12" HORIZONTAL SEPARATION.</p> <p>6) FURNISH AND INSTALL PULL STRING IN EACH CONDUIT.</p> |
|---|--|

IMPORTANT

DITCH AND CONDUIT INSPECTION IS REQUIRED BY W.R.E.C.C. BEFORE BACKFILLING CAN BEGIN. FAILURE TO DO SO WILL REQUIRE THE BACKFILLING TO BE REMOVED.

NAME: PrimaryDitchDetail_1A.dwg DATE: OCT 30, 2013 TIME: 8:55 AM