



SECONDARY DITCH DETAIL 1A

N.T.S.

NOTES:

- | | |
|--|--|
| <p>1) CONDUIT SHALL BE PVC, SCHEDULE 40 ELECTRICAL GRADE PVC, SIZE AND NUMBER AS SPECIFIED ON PLANS. SWEEPS SHALL BE SCHEDULE 40 FOR LESS THAN 150' AND SCHEDULE 80 OVER 150' (18" RADIUS MINIMUM).</p> <p>2) CONDUIT SHALL HAVE A MINIMUM OF 24" COVER TO FINAL GRADE.</p> <p>3) WARNING TAPE SHALL BE INSTALLED THE LENGTH OF THE TRENCH AT LEAST 12" ABOVE CONDUIT.</p> | <p>4) TELEPHONE OR CABLE UTILITY MINIMUM SEPARATION FROM W.R.E.C.C. DUCTS SHALL BE 12" PARALLEL AND 12" VERTICAL.</p> <p>5) ALL FOREIGN UTILITY PERPENDICULAR CROSSINGS MUST HAVE 12" MINIMUM SEPARATION FROM W.R.E.C.C. DUCT.</p> <p>6) CONDUITS RUNNING HORIZONTAL TO WATER OR GAS LINES MUST HAVE A MINIMUM 12" HORIZONTAL SEPARATION.</p> <p>7) FURNISH AND INSTALL PULL STRING IN EACH CONDUIT.</p> |
|--|--|

IMPORTANT

DITCH AND CONDUIT INSPECTION IS REQUIRED BY W.R.E.C.C. BEFORE BACKFILLING CAN BEGIN. FAILURE TO DO SO WILL REQUIRE THE BACKFILLING TO BE REMOVED.