



**NOTES:**

CONDUIT TO BE PVC SCHEDULE 80 ABOVE GRADE AND SCHEDULE 40 BELOW GRADE.

CONTINUOUS RUN OF CONDUIT LIMITED TO (3) 90° BENDS TO POLE. EXTEND CONDUIT TO WARREN RECC WOOD STAKE. IF STAKE IS ON POWER POLE, EXTEND CONDUIT 1'-0" ABOVE GROUND AND STRAP TO POLE. CAP OR CLOSE OPEN ENDS OF CONDUIT.

INSTALL SLIP JOINT SECURELY TO WOOD SUPPORT WITH PIPE STRAP.

**Warren RECC**  
RURAL ELECTRIC COOPERATIVE CORPORATION

951 FAIRVIEW AVENUE • BOWLING GREEN, KY 42102 • 270.842-6541

Designed by	Checked by GSW	DISTRIBUTION CENTER WITH SLIP JOINT
Approved by	Drawn by WMB	Autocad File: DIST_CENTER2.DWG
Date DECEMBER, 2008	Scale NOT TO SCALE	Drawing Name: <b>DC-2A</b>

REV	DATE	REVISION

NAME: Dist\_Center2.dwg DATE: DEC 02, 2008 TIME: 2:20 PM