



PRIMARY DITCH DETAIL

N.T.S.

NOTES:

- 1) CONDUIT SHALL BE PVC, SCHEDULE 40 ELECTRICAL GRADE PVC, SIZE AND NO. AS SPECIFIED ON PLANS.
- 2) PROVIDE 2" SEPARATION BETWEEN CONDUITS.
- 3) WARNING TAPE SHALL BE INSTALLED THE LENGTH OF THE TRENCH AT LEAST 12" ABOVE CONDUIT.