



SECONDARY DITCH DETAIL
 (1" TO 2½" CONDUIT)
 N.T.S.

NOTES:

- 1) CONDUIT SHALL BE PVC, SCHEDULE 40 ELECTRICAL GRADE PVC, SIZE AND NO. AS SPECIFIED ON PLANS.
- 2) CONDUIT SHALL HAVE A MINIMUM OF 24" COVER TO FINAL GRADE.
- 3) WARNING TAPE SHALL BE INSTALLED THE LENGTH OF THE TRENCH AT LEAST 12" ABOVE CONDUIT.

NAME: SecondaryDitchDetail24A.dwg DATE: FEB 04, 2011 TIME: 7:59 AM